

Accession No.	WA-037-2017	Date and time of:	
Laboratory No.	B-0159-2017	Collection	4:45 AM January 23, 2017
		Receipt	10:55 AM January 23, 2017
		Examination	from 1:00 PM January 23, 2017
Submitted by:		to	January 27, 2017
Name	LIANGA WATER DISTRICT		
	RIZAL STREET, LIANGA,		
	SURIGAO DEL SUR		
	DAVAO CITY		
Source (Raw Water)	Develop Spring	Treated water	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Treatment Done:	Chlorination		
Description:	Clear	Drinking Water	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Sampling Point:	Sample 1: Ivy Sechangco Residence' Faucet located at Zone 1, Phase II of LIANGA WATER DISTRICT located at Surigao Del Sur Davao City		
Remarks:			

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	0 MPN/100ml	PASSED
Fecal Coliforms	0 MPN/100ml	
Standard Plate Count	2 cfu/ml	
<hr/>		
	Refilling Station	Public Water Supplies
MPN/100ml -Total Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
MPN/100ml Fecal Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
Standard Plate Count	Less than 500 cfu/ml	Less than 500 cfu/ml

Note: This report shall not be reproduced, except in full, without the approval of DOH CHD-DR and is not valid for purposes of advertising or sales promotion.

[illegible]

Analyst:


Learrie Faye B. Juaman
Medical Technologist II

Certified correct

Maria Erlinda G. Dayoan
Chemist III

Noted by:

Marlon M. Maramion, M.D., FPSP
Pathologist



Accession No.	WA-037-2017	Date and time of:	
Laboratory No.	B-0161-2017	Collection	5:15 AM January 23, 2017
		Receipt	10:55 AM January 23, 2017
		Examination	1:00 PM January 23, 2017
Submitted by:		from to	January 27, 2017

Name LIANGA WATER DISTRICT
RIZAL STREET, LIANGA,
SURIGAO DEL SUR
DAVAO CITY

Source (Raw Water) Develop Spring Treated water ☒ Yes ☐ No
Treatment Done: Chlorination

Description: Clear Drinking Water ☒ Yes ☐ No
Sampling Point: Sample 3: Mercy Abergas Residence, Faucet located at Zone 4, Phase 4, Barangay Diatagon of *LIANGA WATER DISTRICT* located at Surigao Del Sur Davao City

[illegible]

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
Total Coliforms	0 MPN/100ml	PASSED
Fecal Coliforms	0 MPN/100ml	
Standard Plate Count	2 cfu/ml	

	Refilling Station	Public Water Supplies
MPN/100ml: Total Coliforms	Less than 1:1 or 0	Less than 1:1 or 0
MPN/100ml: Fecal Coliforms	Less than 1:1 or 0	Less than 1:1 or 0
Standard Plate Count	Less than 500 cfu/ml	Less than 500 cfu/ml

Note: This report shall not be reproduced, except in full, without the approval of DOH CHD-DR and is not valid for purposes of advertising or sales promotion.

[illegible]


Analyst: Learrie Faye B. Juaman
Medical Technologist II

Certified correct: 
Maria Erlinda G. Dayoan
Chemist III

Noted by: Marlon M. Maramba, M.D., FPSP
Pathologist



Republic of the Philippines
DEPARTMENT OF HEALTH
Center For Health Development For Davao Region
SOUTHERN PHILIPPINES MEDICAL CENTER
REGIONAL PUBLIC HEALTH LABORATORY
Davao City



Accession No.	WA-037-2017	Date and time of:	
Laboratory No.	B-0160-2017	Collection	5:00 AM January 23, 2017
		Receipt	10:55 AM January 23, 2017
		Examination	1:00 PM January 23, 2017
Submitted by:		from to	January 27, 2017

Name LIANGA WATER DISTRICT
RIZAL STREET, LIANGA,
SURIGAO DEL SUR
DAVAO CITY

Source: (Raw Water) Develop Spring Treated water ☒ Yes ☐ No
Treatment Done: Chlorination

Description: Clear Drinking Water ☒ Yes ☐ No
Sampling Point: Sample 2: Analyn Maghinay Residence' Faucet located at Zone 7,Phase
1, Barangay Baucawe of LIANGA WATER DISTRICT' located at
Surigao Del Sur Davao City

[illegible]

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT

Result of Analysis

Remarks

Total Coliforms

0 MPN/100ml

PASSED

Fecal Coliforms

0 MPN/100ml

Standard Plate Count

23 cfu/ml

Refilling Station

Public Water Supplies

MPN/100ml. Total Coliforms

Less than 1.1 or 0

Less than 1, 1 or 0

MPN/100ml. Fecal Coliforms

Less than 1.1 or 0

Less than 1.1 or 0

Standard Plate Count

Less than 500 cfu/ml

Less than 500 cfu/ml

Note: This report shall not be reproduced, except in full, without the approval of DOH CHD-DR and is not valid for purposes of advertising or sales promotion.

[illegible]

-Analyst:

Learrie Faye B. Juaman
Medical Technologist II

Certified correct:

Maria Erlinda G. Dayoan
Chemist III

Noted by:

Marlon M. Maramba, M.D., FPSP

Pathologist