





Pathologist



Pathologist



SPMCSPMCS

Accession No.	WA-581-2017	Date and time of:		
Laboratory No.	B-1796-2017	Collection	05:05 AM	July 11, 2017
		Receipt	09:10 AM	July 11, 2017
		Examination	from 1:00 PM	July 11, 2017
Submitted by:			to 1:00 PM	July 14, 2017

Name LIANGA WATER DISTRICT
Address RIZAL STREET LIANGA,
SURIGAO DEL SUR

Source <i>(Raw Water)</i>	Developed spring	Treated water	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Treatment Done:	Chlorination			
Description:	Clear	Drinking Water	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Sampling Point:	Sample 4: Faucet at the Oscar Solamo Residence located at Zone 1 Purok 1 Lianga. Submitted by Lianga Water District			

Remarks: E.D. CAGAN HENNEBROOK VALE © BLEN

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT	Result of Analysis	Remarks
--------------	--------------------	---------

Total Coliforms	0 MPN/100ml	PASSED
Fecal Coliforms	0 MPN/100ml	
Standard Plate Count	<1.0 cfu/ml	

	Refilling Station	Public Water Supplies
MPN/100ml. Total Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
MPN/100ml. Fecal Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
Standard Plate Count	Less than 500 cfu/ml	Less than 500 cfu/ml

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

Analyst:

Josephine R. Vergara
Medical Technologist II

Certified correct:

Maria Erlinda G. Dayoan
Chemist III

Noted by:

Marlon M. Maramion, M.D., FPSP

Pathologist