



Accession No. WA-494-2017

Date and time of:

Laboratory No. B-1509-2017

Collection 4:00 AM June 05, 2017

Receipt 9:30 AM June 05, 2017

Examination from 1:00 PM June 05, 2017

Submitted by: _____ to _____ June 09, 2017

Name LIANGA WATER DISTRICT

Address RIZAL STREET LIANGA,

SURIGAO DEL SUR

Source (Raw Water): Local waterworks Treated water ☒ Yes ☐ No

Treatment Done: Chlorination

Description: Clear Drinking Water ☒ Yes ☐ No

Sampling Point: Sample 1: Faucet at the Domingo Buar located at Zone-4 Purok 2

Diatagon of Lianga Water District Surigao Del Sur

Remarks:

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT

Result of Analysis

Remarks

Total Coliforms 0 MPN/100ml **PASSED**

Fecal Coliforms 0 MPN/100ml

Standard Plate Count	<1.0 cfu/ml
----------------------	-------------

11/11/2011 11:11:11 AM

Refilling Station

Public Water Supplies

MPN/100ml. Total Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
----------------------------	--------------------	--------------------

MPN/100ml. Fecal Coliforms Less than 1.1 or 0 Less than 1.1 or 0

Standard Plate Count	Less than 500 cfu/ml	Less than 500 cfu/ml
----------------------	----------------------	----------------------

Note: This report shall not be reproduced, except in full, without the approval of DOH CHD-DR and is not valid for purposes of advertising or sales promotion.

[illegible]

Analyst:

Gerardine S. Basañez

Medical Technologist III

Certified correct:

Maria Erlinda G. Dayoan

Chemist III

Noted by:

Marlon M. Maramion, M.D., FPSP

Pathologist



Accession No.	WA-494-2017	Date and time of:	
Laboratory No.	B-1510-2017	Collection	4:15 AM June 05, 2017
		Receipt	9:30 AM June 05, 2017
		Examination	1:00 PM June 05, 2017
Submitted by:		from to	June 09, 2017
Name	LIANGA WATER DISTRICT		
Address	RIZAL STREET LIANGA,		
	SURIGAO DEL SUR		

Source (Raw Water): Local waterworks Treated water ☒ Yes ☐ No
Treatment Done: Chlorination

Description: Clear Drinking Water ☒ Yes ☐ No
Sampling Point: Sample 2: Faucet at the Norife Borja located at Zone-6 Purok 6
Causeway St. Christine of Lianga Water District Surigao Del Sur

Remarks:

BACTERIOLOGICAL EXAMINATION OF WATER

Method- MTFT

Result of Analysis

Remarks

Total Coliforms	0 MPN/100ml	PASSED
Fecal Coliforms	0 MPN/100ml	
Standard Plate Count	5 cfu/ml	

	Refilling Station	Public Water Supplies
MPN/100ml. Total Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
MPN/100ml. Fecal Coliforms	Less than 1.1 or 0	Less than 1.1 or 0
Standard Plate Count	Less than 500 cfu/ml	Less than 500 cfu/ml

Note: This report shall not be reproduced, except in full, without the approval of DOH CHD-DR and is not valid for purposes of advertising or sales promotion.

Analyst:

Gerardine S. Basañez

Medical Technologist III

Certified correct:

Maria Erlinda G. Dayoan

Chemist III

Noted by:

Marlon M. Maramion, M.D., FPSP

Pathologist

