






Pathologist





Pathologist



Pathologist



Pathologist



Accession No.	WA-747-2017	Date and time of:	
Laboratory No.	B-2273-2017	Collection	08:00 AM Sept. 5, 2017
		Receipt	09:50 AM Sept. 5, 2017
		Examination	1:00 PM Sept. 5, 2017
Submitted by		from to	Sept. 12, 2017

Name LIANGA WATER DISTRICT
Address RIZAL STREET LIANGA
SURIGAO DEL SUR

Source (Raw Water):	Developed spring
Treatment Done:	Chlorination
Description:	Clear Drinking Water <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Sampling Point:	Sample 4: Montil Faucet located at Zone 1 National Highway Purok 1, Surigao del Sur.

Remarks: FENICAN CENTER FOR POLITICAL DEVELOPMENT

BACTERIOLOGICAL EXAMINATION OF WATER		
Method- MTFT	Result of Analysis	Remarks
Total Coliforms	<1.1 MPN/100mL	PASSED
Fecal Coliforms	<1.1 MPN/100mL	
Standard Plate Count	60 CFU/mL	
Limits	Refilling Station	Public Water Supplies
MPN/100ml. Total Coliforms	Less than 1 (<1.1) or 0	Less than 1 (<1.1) or 0
MPN/100ml. Fecal Coliforms	Less than 1 (<1.1) or 0	Less than 1 (<1.1) or 0
CFU/ml. Standard Plate Count	Less than 500	Less than 500

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

[illegible]

Analyst:

Josephine R. Vergara
Medical Technologist II

Certified correct:

Maria Erlinda G. Dayoan
Chemist III

Noted by:

Marlon M. Maramion, M.D., FPSP
Pathologist