

Beyond Providing Water

Republic of the Philippines  
**SAN FRANCISCO WATER DISTRICT**  
San Francisco, Agusan del Sur

**SAN FRANCISCO WATER DISTRICT LABORATORY**  
(DOH Accreditation No.: 16-002-16-LW-1)

**WATER BACTERIOLOGICAL EXAMINATION**

**CLIENT'S INFORMATION**

Date: July 21, 2020

Requested by : Lianga Water District  
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur  
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

**SAMPLE'S INFORMATION**

**LABORATORY'S INFORMATION**

Date and time of collection : July 14, 2020 -  
Location of sampling point : L. Malayno, Zone-1 P-1 Lianga  
Surigao del Sur  
Sample source : Surface water  
Sampling point : Faucet  
Treatment process : None  
Disinfection process : Chlorine  
Analyte/Sample Identity : Product

Sample No. : B20-07-1807  
Physical characteristics : Clear  
Date examined : July 14, 2020  
Date paid / O.R. no. : July 14, 2020 - 543302

**LABORATORY RESULTS**

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.  
Water sample is negative of both total and fecal coliform organisms.  
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO  
(Cert. No. WMLA 12-0223)  
U/CSO-A/CWPS

MAMRY B. PAYLANGCO  
Division Manager C

EMERIT T. LUZON  
General Manager C

Released by: JEAN MARIE S. SIB  
Name and Signature

Received by: JEFF MORALES  
Name and Signature

Date: JUL 20 2020

Date: 7/27/20



Beyond Providing Water

Republic of the Philippines  
SAN FRANCISCO WATER DISTRICT  
San Francisco, Agusan del Sur

**SAN FRANCISCO WATER DISTRICT LABORATORY**  
(DOH Accreditation No.: 16-002-16-LW-1)

**WATER BACTERIOLOGICAL EXAMINATION**

**CLIENT'S INFORMATION**

Requested by : Lianga Water District  
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur  
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: July 21, 2020

**SAMPLE'S INFORMATION**

Date and time of collection : July 14, 2020 - 7:32am  
Location of sampling point : J. Chico, Zone-9 P-1 Brgy. Wakat  
Barobo, Surigao del Sur  
Sample source : Developed spring  
Sampling point : Faucet  
Treatment process : None  
Disinfection process : Chlorine  
Analyte/Sample Identity : Product

**LABORATORY'S INFORMATION**

Sample No. : B20-07-1805  
Physical characteristics : Clear  
Date examined : July 14, 2020  
Date paid / O.R. no. : July 14, 2020 - 543302

**LABORATORY RESULTS**

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	3	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVERA P. COMPLETO

(Cert. No. WMLA 12-0223)

U/CSO-A/CWPS

Released by: LEANN M. BAYASIG  
Name and Signature

Date: JUL 28 2020

Approved:



7/22/2020  
MAMRY B. PAYLANGCO  
Division Manager C

Noted:

ELMER T. LUZON  
General Manager C

Received by: JEFFREY M. SANCHEZ  
Name and Signature

Date: 7/27/20



Republic of the Philippines  
**SAN FRANCISCO WATER DISTRICT**  
San Francisco, Agusan del Sur

**SAN FRANCISCO WATER DISTRICT LABORATORY**  
(DOH Accreditation No.: 16-002-16-LW-1)

**WATER BACTERIOLOGICAL EXAMINATION**

CLIENT'S INFORMATION

Requested by : Lianga Water District  
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur  
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: July 21, 2020

SAMPLE'S INFORMATION

Date and time of collection : July 14, 2020 - 7:47am  
Location of sampling point : Fe Borja, Zone-8 P-4 Brgy.  
Liatimco  
Sample source : Developed spring (surface water)  
Sampling point : Faucet  
Treatment process : None  
Disinfection process : Chlorine  
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-07-1806  
Physical characteristics : Clear  
Date examined : July 14, 2020  
Date paid / O.R. no. : July 14, 2020 - 543302

**LABORATORY RESULTS**

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.  
Water sample is negative of both total and fecal coliform organisms.  
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO  
(Cert. No. WMLA 12-0223)  
U/CSO-A/QWPS

Released by: LEANDRO DAMASIS  
Name and Signature

Date: JUL 27 2020

Approved:


7/22/2020  
MAMRY B. PAYLANGCO  
Division Manager C

Noted:

ELMERT T. LUZON  
General Manager C

Received by: JEFF HANCOCK  
Name and Signature

Date: 7/27/20



Republic of the Philippines  
**SAN FRANCISCO WATER DISTRICT**  
San Francisco, Agusan del Sur

**SAN FRANCISCO WATER DISTRICT LABORATORY**  
(DOH Accreditation No.: 16-002-16-LW-1)

**WATER BACTERIOLOGICAL EXAMINATION**

**CLIENT'S INFORMATION**

Date: August 5, 2020

Requested by : Lianga Water District  
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur  
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

**SAMPLE'S INFORMATION**

Date and time of collection : July 28, 2020 - 7:27am  
Location of sampling point : M. Torbolinto, Zone-6 P-3

Sample source : Surface water  
Sampling point : Faucet  
Treatment process : None  
Disinfection process : Chlorine  
Analyte/Sample Identity : Product

**LABORATORY'S INFORMATION**

Sample No. : B20-07-1948  
Physical characteristics : Clear  
Date examined : July 28, 2020  
Date paid / O.R. no. : July 28, 2020 - 546082

**LABORATORY RESULTS**

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO  
(Cert. No. WMLA 12-0223)  
U/CSO-A/QWPS

Released by: KEAM L. DARASIO  
Name and Signature

Date: 10/1/2020

Approved:


8/6/2020  
MAMRY B. DAYLANGCO  
Division Manager C

Noted:

ELMER T. LUZON  
General Manager C

Received by: \_\_\_\_\_  
Name and Signature

Date: \_\_\_\_\_



Beyond Providing Water...

Republic of the Philippines  
**SAN FRANCISCO WATER DISTRICT**  
San Francisco, Agusan del Sur

**SAN FRANCISCO WATER DISTRICT LABORATORY**  
(DOH Accreditation No.: 16-002-16-LW-1)

**WATER BACTERIOLOGICAL EXAMINATION**

**CLIENT'S INFORMATION**

Date: August 5, 2020

Requested by : Lianga Water District  
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur  
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

**SAMPLE'S INFORMATION**

Date and time of collection : July 28, 2020 - 7:06am  
Location of sampling point : L. Madrid, Zone-5 P-2 Public  
Market, Diatagon  
Sample source : Surface water  
Sampling point : Faucet  
Treatment process : None  
Disinfection process : Chlorine  
Analyte/Sample Identity : Product

**LABORATORY'S INFORMATION**

Sample No. : B20-07-1947  
Physical characteristics : Clear  
Date examined : July 28, 2020  
Date paid / O.R. no. : July 28, 2020 - 546082

**LABORATORY RESULTS**

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO  
(Cert. No. WMLA 12-0223)  
U/CSO-A/QWPS

Approved:

8/6/2020  
MAMIRY B. PAYLANGCO  
Division Manager C

Noted:

ELMER T. LUZON  
General Manager C

Released by: LEANDY BERNASCO  
Name and Signature

Date: Aug 11 2020

Received by: \_\_\_\_\_  
Name and Signature

Date: \_\_\_\_\_



Republic of the Philippines  
**SAN FRANCISCO WATER DISTRICT**  
San Francisco, Agusan del Sur

**SAN FRANCISCO WATER DISTRICT LABORATORY**  
(DOH Accreditation No.: 16-002-16-LW-1)

**WATER BACTERIOLOGICAL EXAMINATION**

**CLIENT'S INFORMATION**

Requested by : Lianga Water District  
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur  
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: August 5, 2020

**SAMPLE'S INFORMATION**

Date and time of collection : July 28, 2020 - 6:56am  
Location of sampling point : Fe Alvarado, Zone-4 P-1, Dylm,  
Diatagon  
Sample source : Surface water  
Sampling point : Faucet  
Treatment process : None  
Disinfection process : Chlorine  
Analyte/Sample Identity : Product

**LABORATORY'S INFORMATION**

Sample No. : B20-07-1946  
Physical characteristics : Clear  
Date examined : July 28, 2020  
Date paid / O.R. no. : July 28, 2020 - 546082

**LABORATORY RESULTS**

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.  
: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.  
Water sample is negative of both total and fecal coliform organisms.  
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO  
(Cert. No. WMLA 12-0223)  
U/CSO-A/QWPS

Released by: LEAH V. CANASIG  
Name and Signature

Date: AUG 11 2020

Approved:

8/6/2020  
MAMRYB. PAYLANGCO  
Division Manager C

Noted:

ELMER T. LUZON  
General Manager C

Received by: \_\_\_\_\_  
Name and Signature

Date: \_\_\_\_\_