

Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: May 20, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : May 12, 2020 - 7:09am
Location of sampling point : Nestor Delatore, Zone-1, P-7, Ago,
Lianga, Surigao del Sur
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-05-1208
Physical characteristics : Clear
Date examined : May 12, 2020
Date paid / O.R. no. : May 12, 2020 - 523350

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C


ELMER T. LUZON
General Manager C

Released by: **CYD OLIVETTE P. COMPLETO, RMT**
Name and Signature

Date: 5/28/20

Received by: **MARIA F. BAYAR**
Name and Signature

Date: 5-28-20



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: May 20, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : May 12, 2020 - 6:57am
Location of sampling point : Ronan Decastro, Zone-2, P-1,
Tigis, Lianga, Surigao del Sur
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-05-1207
Physical characteristics : Clear
Date examined : May 12, 2020
Date paid / O.R. no. : May 12, 2020 - 523350

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C


ELMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO, RMT
Name and Signature

Date: May 20, 2020

Received by: ANTHONY P. BANG
Name and Signature

Date: May 20, 2020



Beiping Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: May 20, 2020

SAMPLE'S INFORMATION

Date and time of collection : May 12, 2020 - 7:29am
Location of sampling point : Ernesto Tubil, Zone-8, P-1,
Liatimco, Lianga, Surigao del Sur
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-05-1209
Physical characteristics : Clear
Date examined : May 12, 2020
Date paid / O.R. no. : May 12, 2020 - 523350

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	3	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C

ELMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO, RMT


Received by: ARNOLD P. BAYAN

Name and Signature

Name and Signature

Date: 5/28/20

Date: 5-28-20



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: May 20, 2020

SAMPLE'S INFORMATION

Date and time of collection : May 12, 2020 - 6:25am
Location of sampling point : Romel Ursales, Zone-6, P-4

Saint Christine

Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-05-1206
Physical characteristics : Clear
Date examined : May 12, 2020
Date paid / O.R. no. : May 12, 2020 - 523350

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.
: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

5/22/2020
MARRY B. PAYLANGCO
Division Manager C


ELMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO, RMT
Name and Signature

Date: 5/28/20

Received by: MARRY B. PAYLANGCO
Name and Signature

Date: 5/28/20



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: May 20, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : May 12, 2020 - 6:02am
Location of sampling point : Jollana Roxas, Zone-5 P-1, Dylm,
Diatagon
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-05-1204
Physical characteristics : Clear
Date examined : May 12, 2020
Date paid / O.R. no. : May 12, 2020 - 523350

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	210	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C

ELMERT L. UZON
General Manager C


Released by: CYD OLIVETTE P. COMPLETO, RMT

Received by: ANASTACIO P. BAYAN
Name and Signature

Name and Signature

Date: 5/28/20

Date: 05-28-20



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: May 20, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A, Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : May 12, 2020 - 6:16am
Location of sampling point : Meguilito Granaderos, Zone-5,
P-2 Rechiemer, Diatagon
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-05-1205
Physical characteristics : Clear
Date examined : May 12, 2020
Date paid / O.R. no. : May 12, 2020 - 523350

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	29	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C

ELMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO, RMT

Received by: ANASTACIO P. BARRERA
Name and Signature

Date: 5/28/20

Date: 5/28/20