



Pathologist



| | | | | |
|-----------------|---|-------------------|---|-----------------------------|
| Laboratory No. | B-0411-2020 | Date and time of: | | |
| | | Collection | 5:18 AM | Feb. 11,2020 |
| | | Receipt | 10:26 AM | Feb. 11,2020 |
| | | Examination | from 1:00 PM | Feb. 11,2020 |
| | | | to | Feb. 17,2020 |
| Submitted by: | | | | |
| Name | WILFREDO G. SANCHEZ | | | |
| Address | LIANGA WATER DISTRICT | | | |
| | ANNEX – A, MARKET MALL, LIANGA, | | | |
| | SURIGAO DEL SUR | | | |
| Source: | Developed spring | | | |
| Treatment Done: | Chlorination | | | |
| Description: | Clear | Drinking Water | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No |
| Sampling Point: | Sample 5 : Pedro Nalla faucet at Zone 5 Purok 5 DYLM Barangay , | | | |
| | Diatagon, submitted by LIANGA WATER DISTRICT | | | |
| Remarks: | | | | |

BACTERIOLOGICAL EXAMINATION OF WATER

| Method- MTFT | Result of Analysis | Remarks |
|---------------------------------|--------------------|---------|
| Total Coliforms | <1.1 MPN/100mL | PASSED |
| Thermotolerant(Fecal) Coliforms | <1.1 MPN/100mL | |
| Standard Plate Count | 2 CFU/mL | |

Limits

MPN/100ml. Total Coliforms
MPN/100ml. Fecal Coliforms
CFU/ml. Standard Plate Count

Public Water Supplies

Less than 1 (<1.1) or 0
Less than 1 (<1.1) or 0
Less than 500

Note: Results of examination are specifically related to samples as received. This report shall not be reproduced, except in full, without the approval of RPHL – SPMC and is not valid for purposes of advertising or sales promotion.

[illegible]

Analyst:

Josephine R. Vergara
Medical Technologist II

Certified correct

Maria Erlinda G. Dayoan
Chemist III

Noted by:

Ma. Theresa Fedoc, RMT, MD, DPSP

Lic. No. 0124838

Pathologist

