



FORM I - STANDARD FORMAT FOR MICROBIOLOGICAL TEST RESULTS

(Instruction: Fill up the yellow-colored cells)

LIANGA

WATER DISTRICT

Province: Surigao del Sur

SUMMARY REPORT ON MICROBIOLOGICAL TEST

MONTH OF SEPTEMBER 20 20

1 . Population actually served by utility:
(No. of service connections x ave. no. of persons per service connection (5 persons per household) 17,960

No. of service connections 3,592

2 . Required minimum number of samples based on the table below:

2.a For Total Coliform & Thermotolerant Coliform/E.Coli 6 samples

2.b For Heterotrophic Plate Count 6 samples

Population Served	Minimum Frequency of Sampling for Total Coliform and Thermotolerant Coliform/E. coli	Minimum Frequency of Sampling for Heterotrophic Plate Count (HPC)	Point of Compliance
Less than 5,000	2 samples monthly	2 samples monthly	Consumers' taps
5,000 - 100,000	1 sample per 5,000 population + 2 additional samples monthly	1 sample per 5,000 population + 2 additional samples monthly	Consumers' taps
More than 100,000	1 sample per 10,000 population + 12 additional samples monthly	Required at least 40% of the sampling points	Consumers' taps
Note: Collection of samples should be spread out within a month			

3 . Sample Requirement

a . No. of samples examined. 6

b . Percent (%) to the minimum required. 100.0%

c . Met Standards? Yes Yes No No
("Yes" if b is 100% or more. "No" if b is less than 100%.)

4 . Parameter/Method

A. Total Coliform

4.1 Multiple Tube Fermentation Technique (MTFT)

a . Number of samples showing presence of coliform group. 0

b . Percent (%) to samples examined (4.1.a/3.a x 100). 0.0%

c . Met Standards? Yes Yes No No
("Yes" if b is 5% or less. "No" if b is more than 5%.)

4.2 Membrane Filter Technique (MFT)

a . Number of samples showing presence of coliform colonies. 0

b . Percent (%) to the number of samples analyzed. 0.0%
(4.2.a/3.a x 100)

c . Met Standards? Yes Yes No No
("Yes" if b is 5% or less. "No" if b is more than 5%.)

4.3 Enzyme Substrate Coliform Test (EST)

- a . Number of samples showing presence of coliform.
- b . Percent (%) to total number of samples examined. 0.0%
(4.3.a/3.a x 100)
- c . Met Standards? ☐ Yes ☒ No No
(“Yes” if b is 5% or less. “No” if b is more than 5%.)

B. Thermotolerant Coliform/ E. coli

- a . Number of samples showing presenvce of thermotolerant coliform/E. coli organisms.
MTFT: MPN/100 ml value of < 1.1
EST: Absent or < 1 MPN/100 ml
MFT: < 1 thermotolerant coliform colonies/100ml. 0
- b . Percent (%) to total number of samples analyzed 0.0%
- c . Met Standards? ☒ Yes ☐ No
(“Yes” if a is zero. “No” if a is not equal to zero.)

C. Heterotrophic Plate Count (HPC)

- a . Number of HPC tests conducted. 6
Percent (%) to the minimum required. 100.0%
Met Standards (no. of samples)? ☒ Yes ☐ No
- b . No. of samples showing HPC value < 500 CFU/ml. 6
- c . Percent (%) to number of tests conducted (b/a x 100). 100.0%
- d . Met Standards? ☒ Yes ☐ No
(“Yes” if c is 100%. “No” if c is not 100%.)

5 DISINFECTION RESIDUAL

5.A Using Free Residual Chlorine

- a . No. of days without a test conducted 0
- b . No. of samples with residual chlorine <0.3 or >1.5 mg/L 0
- c . Met Standards? ☒ Yes ☐ No
(“Yes” if a and b are both zero. “No” if either a or b, or both a and b are not zero.)

5.B Using Chlorine Dioxide


- a . No. of days without a test conducted 0
- b . No. of samples with residual chlorine dioxide <0.2 or >0.4 mg/L 0
- c . Met Standards? ☒ Yes ☐ No
(“Yes” if a and b are both zero. “No” if either a or b, or both a and b are not zero.)

NOTE: FOR MICROBIOLOGICAL RESULTS:
If number of samples is 20 or less, please attach laboratory test results with this summary form.
number of samples is more than 20, only the summary form is required even without accompanying laboratory test results

SUBMITTED BY:



WILFREDO G. SANCHEZ
General Manager



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: September 21, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : September 8, 2020 - 7:00am
Location of sampling point : T. Tabigue, Zone-1 Pugad
Purok-3
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-09-2405
Physical characteristics : Clear
Date examined : September 8, 2020
Date paid / O.R. no. : September 8, 2020 - 556044

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C

ELMER T. LUZON
General Manager C

Released by: ELMER T. LUZON
Name and Signature

Received by: _____
Name and Signature

Date: SEP 22 2020

Date: _____

(085) 839-0457 or 343-8623

+63 928-375-5851

sanfranzwd@gmail.com

www.sfwd.gov.ph

2019-07-21
Rev. No. 00, 2019



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: September 21, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : September 8, 2020 - 7:15am
Location of sampling point : F. Gonzaga, Zone-2 Purok-2
Lianga, Surigao del Sur
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-09-2406
Physical characteristics : Clear
Date examined : September 8, 2020
Date paid / O.R. no. : September 8, 2020 - 556044

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. DAYLANGCO
Division Manager C

ELMER T. LUZON
General Manager C

Released by: LEAN V. PANOSIC
Name and Signature

Received by: _____
Name and Signature

Date: SEP 22 2020

Date: _____

(085) 839-0457 or 343-8623

+63 928-375-5851

sanfranzwd@gmail.com

www.sfwd.gov.ph

2019-07-21

Rev. No. 00, 2019



Beyond Providing Water.

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: September 21, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : September 8, 2020 - 5:40am
Location of sampling point : T. Cuajotor, Zone-4 Public
Market, Diatagon
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-09-2407
Physical characteristics : Clear
Date examined : September 8, 2020
Date paid / O.R. no. : September 8, 2020 - 556044

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

Approved:

Noted:

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

MAMRY B. PAYLANGCO
Division Manager C

ELMER T. LUZON
General Manager C

Released by: LEAN V. SANASIO
Name and Signature

Date: SEP 22 2020

Received by: _____
Name and Signature

Date: _____

(085) 839-0457 or 343-8623

+63 928-375-5851

sanfranzwd@gmail.com

www.sfwd.gov.ph

2019-07-21
Rev. No. 00, 2019



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: September 21, 2020

SAMPLE'S INFORMATION

Date and time of collection : September 8, 2020 - 5:55am
Location of sampling point : P. Malbas, Zone-5 Boundary
Diatagon
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-09-2408
Physical characteristics : Clear
Date examined : September 8, 2020
Date paid / O.R. no. : September 8, 2020 - 556044

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.
: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVERTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Released by: LEAN V. B. MASIG
Name and Signature

Date: SEP 21 2020
SEP 21 2020

Approved:


MAMRY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. LUZON
General Manager C

Received by: _____
Name and Signature

Date: _____



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: September 21, 2020

SAMPLE'S INFORMATION

Date and time of collection : September 8, 2020 - 6:05am
Location of sampling point : Embasaldo, Zone-6 Purok-4
Brgy. Hall St. Christine
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-09-2409
Physical characteristics : Clear
Date examined : September 8, 2020
Date paid / O.R. no. : September 8, 2020 - 556044

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.
: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Approved:

MARY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. MUZON
General Manager C

Released by: LEAN V. BAKASIS

Name and Signature

Date: SEP 22 2020

Received by:

Name and Signature

Date:



Beyond Providing Water

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: September 21, 2020

SAMPLE'S INFORMATION

Date and time of collection : September 8, 2020 - 6:37am
Location of sampling point : E. Espuerta, Zone-8 Purok 2
Brgy. Liatimco
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-09-2404
Physical characteristics : Clear
Date examined : September 8, 2020
Date paid / O.R. no. : September 8, 2020 - 556044

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.
: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Released by: LEAN V. BANSIO
Name and Signature
Date: _____

Approved:

9/22/2020
MAMRY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. LUZON
General Manager C

Received by: _____
Name and Signature
Date: _____