

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: August 19, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : August 11, 2020 - 6:58am
Location of sampling point : A. Salomon, Zone-2 P-5
: Lianga, Surigao del Sur
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-08-2104
Physical characteristics : Clear
Date examined : August 11, 2020
Date paid / O.R. no. : August 11, 2020 - 548697

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Released by CYD OLIVETTE P. COMPLETO, RMT
Name and Signature

Date: AUG 19 / 2020

Approved:


MAMRY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. LUZON
General Manager C

Received by: LESLIE N. PUGER
Name and Signature

Date: 8/24/20



Beyond Providing Water...

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: August 19, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : August 11, 2020 - 6:33am
Location of sampling point : T. Pocon, Zone-3 P-4
Tindugan, Ban-as, Lianga,
Surigao del Sur
Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-08-2103
Physical characteristics : Clear
Date examined : August 11, 2020
Date paid / O.R. no. : August 11, 2020 - 548697

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Approved:


MAMRY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO, RMT
Name and Signature
Date: AUG 24 2020

Received by: LEBLON N. ALFARER
Name and Signature
Date: 8/24/20



Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: August 19, 2020

SAMPLE'S INFORMATION

Date and time of collection : August 11, 2020 - 7:15am
Location of sampling point : E. Aroyo, Zone-7 P-3
: Lianga, Surigao del Sur

Sample source : Developed spring
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-08-2105
Physical characteristics : Clear
Date examined : August 11, 2020
Date paid / O.R. no. : August 11, 2020 - 548697

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Released by: CYD OLIVETTE P. COMPLETO, RMT
Name and Signature

Date: Aug 20 2020

Approved:

MAMRY B. PAYLANGCO
Division Manager C

Noted:

EUMER T. LUZON
General Manager C

Received by: LESLIE R. ALVAREZ
Name and Signature

Date: 8/24/20



Beyond Providing Water...

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Date: August 19, 2020

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

SAMPLE'S INFORMATION

Date and time of collection : August 11, 2020 - 6:15am
Location of sampling point : M. Padonat, Zone-6 P-6
Causeway, St. Christine

Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-08-2102
Physical characteristics : Clear
Date examined : August 11, 2020
Date paid / O.R. no. : August 11, 2020 - 548697

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	<1	less than 500 cfu/mL	Passed ✓
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed ✓

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.
: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.
Water sample is negative of both total and fecal coliform organisms.
HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Approved:

MAMRY B. PAYLANGCO
Division Manager C

Noted:


EUMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO
Name and Signature

Date: AUG 20 2020

Received by: LEOG M. AVILA
Name and Signature

Date: 8/24/20



Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: August 19, 2020

SAMPLE'S INFORMATION

Date and time of collection : August 11, 2020 - 5:40am
Location of sampling point : M. Granados, Zone-4 P-2,
Diatagon, Lianga, Surigao del Sur
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-08-2100
Physical characteristics : Clear
Date examined : August 11, 2020
Date paid / O.R. no. : August 11, 2020 - 548697

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	1	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVENTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Approved:

MAMRY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. LUZON
General Manager C

Released by: CYD OLIVENTE P. COMPLETO

Name and Signature
Date: AUG 24 2020

Received by: LEBEL M. ALFARER

Name and Signature
Date: 8/24/20



Beyond Providing Water...

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

SAN FRANCISCO WATER DISTRICT LABORATORY
(DOH Accreditation No.: 16-002-16-LW-1)

WATER BACTERIOLOGICAL EXAMINATION

CLIENT'S INFORMATION

Requested by : Lianga Water District
Address of requesting party : Annex-A Market Mall, Lianga, Surigao del Sur
Contact Person & No. : Wilfredo G. Sanchez - 09299757591

Date: August 19, 2020

SAMPLE'S INFORMATION

Date and time of collection : August 11, 2020 - 6:00am
Location of sampling point : C. Plaza, Zone-5 P-4,
Diatagon, Lianga, Surigao del Sur
Sample source : Surface water
Sampling point : Faucet
Treatment process : None
Disinfection process : Chlorine
Analyte/Sample Identity : Product

LABORATORY'S INFORMATION

Sample No. : B20-08-2101
Physical characteristics : Clear
Date examined : August 11, 2020
Date paid / O.R. no. : August 11, 2020 - 548697

LABORATORY RESULTS

PARAMETERS	RESULT OF ANALYSIS	PNSDW (Phil. Nat'l Standards for Drinking Water)	REMARKS
HPC (Heterothropic Plate Count)	1	less than 500 cfu/mL	Passed
Total Coliform	less than 1.1	less than 1.1 (MPN/100 mL)	Passed
Fecal Coliform / Thermotolerant	less than 1.1	less than 1.1 (MPN/100 mL)	Passed

Method of Determination: Multiple Tube Fermentation Technique (MTFT) for Coliform.

: Pour plate method for HPC

Remarks: Result of examination relate only to sample as submitted and tested.

Water sample is negative of both total and fecal coliform organisms.

HPC is within the standard limit set by PNSDW.

I hereby certify that the above data/information are true and correct.

Prepared & Certified Correct

CYD OLIVETTE P. COMPLETO
(Cert. No. WMLA 12-0223)
U/CSO-A/QWPS

Approved:

MAMRY B. PAYLANGCO
Division Manager C

Noted:

ELMER T. LUZON
General Manager C

Released by: CYD OLIVETTE P. COMPLETO

Name and Signature

Date: AUG 19 2020

Received by: LESLIE N. FUERES

Name and Signature

Date: 8/24/20